

ADDENDUM - 01

PROPOSED HVAC WORKS FOR 2ND, 3RD & 4TH FLOOR OF MPCB OFFICE AT SION, MUMBAI

Tender No.:- MPCB/EE/PT/e-Tender-1/2018-19



Maharashtra Pollution Control Board

Kalpataru Point, 3rd& 4thFloor, Sion Matunga Scheme Road No.8

Opp.SionCircle,Sion (East), Mumbai-400 022

Website:<http://mpcb.gov.in>

(2018 – 2019)

PROPOSED HVAC WORKS FOR 2ND, 3RD & 4TH FLOOR OF MPCB OFFICE AT SION, MUMBAI

Pre Bid Meeting Held on 09th March 2018 at MPCB office, 4th Floor, Kalpataru Point, Sion Circle Sion East, Mumbai.

During the course of discussion and query of contractors following addendum are made.

Sr. No	Description	As per Tender	Addendum
1	In Special condition of Contract, clause no. 2.c	Entire amountwithin four months	Entire amountwithin 45 days
2	In Special condition of Contract, clause no. 40 -	Inspection to ware house	Inspection to ware house & Factory visit
3			Bidder has to consider additional 60m length of 100 mm Dia PVC pipe for Ac machines drains in existing plumbing shafts.
4	In Price Schedule	Item No. B-3	Refrigerant piping qty is in lot all the respective vendors quote required pipe sizes based on their system design calculation
5	In Price Schedule	Item No. A-1-c & d	48 HP machine will be single outdoor with inbuilt multiple modules.
6			All the required core cuttings & refilling with fire sealant materials shall be in bidder scope

Note: - The above addendum is the part of existing tender document, thus contractor should be sign and submitted the same with tender document.